

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No. 309Date : 29/04/2021

It is certified that an inspection team headed by **Ashutosh Kumar Rajak, J.E. (P.H.E.D)** from **P.H. Sub-Division, Araria (West)** inspected the **STAR GLOBAL PUBLIC SCHOOL, ARARIA** on Dated **19/04/2021** and found that the **STAR GLOBAL PUBLIC SCHOOL, ARARIA** has **Safe Drinking Water Facilities** for the students and members of staff of the institution and is maintaining the **hygienic sanitation condition** in the school building & the campus as per the norms prescribed by the **Central/State/ U.T Govt.**

The above valid for a period of **One year**

Ashutosh
29/04/2021
J.E

P.H.Subdivision,
Araria West

Signature With Seal : -----

Name

:-- Chandan Kumar --

Designation

:-- Assistant Engineer --

P.H.Sub Division Araria West.

Chandan
29/04/2021
Assistant Engineer
P.H. Sub-Division Araria West

To,

Principal,

Star Global Public School,

Araria - 854312

(Name & Address of The Institution)

Government of Bihar
OFFICE OF THE EXECUTIVE ENGINEER, PUBLIC HEALTH DIVISION ARARIA.
CHEMICAL AND BACTERIOLOGICAL REPORT OF DRINKING WATER SAMPLES

District Name: - ARARIA

Month - APRIL - 2021

SL. No.	Location of Source	Parameters Examined														Remarks	
		pH	Turbidity	Conductivity	TDS	Total Hardness	Calcium	Magnesium	Chloride	Alkalinity	Iron	Nitrate	Sulphate	Fluoride	Arsenic		Bacteria
1	Star Global Public School, Araria.	7.3	0.4	199	123	82	14.4	11.17	40	74	0.31	5.0	10	0.15	BDL	-Ve	Acceptable
	Desirable Limit*	6.5-8.5	1.0	-	500	200	75	30	250	280	1.0	45	200	1.0	0.01	-	-
	Permissible Limit* in absence of alternate source	NR	5.0	-	2000	600	200	100	1000	800	NR	NR	400	1.5	NR	**	-

Note - (i) Drinking Water Specification Second Revision IS: 10500: 2012, (ii) BDL means Below Detection Limit, (iii) NR means no relaxation and (iv) ** Shall not be detectable in any 100ml sample

Kumar
29/04/2021
Chemist
P.H. Division, Araria.

Chandra Kumar
29/04/21
Assistant Engineer
P.H. Sub Division, Araria West.

[Signature]
Executive Engineer
P.H. Division, Araria.